

**From** Director General  
Fire Service, Haryana Panchkula

**To** M/s PM SHRI GSSS PASSINA KHURD  
PASSINA KHURD DISTRICT PANIPAT

**Memo No. FS/2024/432 dated : 27/03/2024**

**Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B- Educational Building at PASSINA KHURD DISTRICT PANIPAT of PM SHRI GSSS PASSINA KHURD :**

Reference your Transaction Id 140842423000088 dated: 22/02/2024 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Panipat Main, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

<b>Tower Name</b>	<b>Floor Detail</b>	<b>Terrace Height of Last Livable Floor(In Meters)</b>	<b>Ground Coverage</b>
BLOCK A	Ground	4.04 mtr.	567.72 Sqm.
BLOCK B	Ground + 1	8.437 mtr.	251.32 Sqm.
BLOCK C	Ground	4.04 mtr.	72.39 Sqm.
BLOCK D	Ground	4.04 mtr.	130.76 Sqm.
BLOCK E	Ground	4.04 mtr.	299.256 Sqm.
BLOCK F	Ground	4.04 mtr.	141.17 Sqm.
BLOCK G	Ground	4.04 mtr.	75 Sqm.
BLOCK H	Ground	4.296 mtr.	141.75 Sqm.
BLOCK I	Ground	4.04 mtr.	296.41 Sqm.
BLOCK J	Ground + 1	8.437 mtr.	74 Sqm.
BLOCK K	Ground	4.04 mtr.	74 Sqm.
BLOCK L	Ground	4.04 mtr.	74 Sqm.
BLOCK M	Ground	4.04 mtr.	99.38 Sqm.
BLOCK N	Ground	4.04 mtr.	25.25 Sqm.

  

<b>Tower Name</b>	<b>Basement Level</b>	<b>Basement Area</b>	<b>Basement Remarks</b>
	Nil	Nil	Nil

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

**Principal**  
**PM Shri G.S.S. School**  
**Passina Khurd (2039)**  
**Panipat**



Deputy Director (Technical)-I,  
for Director General, Fire  
Service, Haryana

Panchkula

Exercising the power of Director, Fire Services, Haryana

Principal  
G.M. Sir, G.S.S. School  
Kashyap Khurd (S.O.S.)  
Panchkula



Digitally signed by GULSHAN  
KALRA  
Date: 2024.03.27 15:41:11 +05:30  
Reason: Digital Verification



## Fire Safety - Undertaking

Category of application : Fresh affiliation upto Senior Secondary level Switch over from other Boards (only schools who are already affiliated to another Board)

I, KRISHAN DUTT, Principal of the school PM SHRI GSSS PASSINA KHURD do hereby undertake that the school run/applied under regular category is unable to obtain / renew Fire Safety Certificate issued from the Fire Safety Department of the State Government/ Competent Government Authority eg. Municipal Corporation etc. of the concerned area till date of application. The school was last inspected for the fire safety on : 08/03/2024

I, assure that before starting of the regular school/commencement of session the above safety certificate will be obtained and submitted. In the meanwhile whole responsibility of the safety and security of staff and students will be on undersigned. Therefore, being a regular category school it may be provisionally allowed.

Principal Sign :

Principal Name :

School Address :

Date :

Place :

Seal :

*KD 28/6/24*  
**Principal  
PM Shri G.S.S. School  
Passina Khurd (2039)  
Panipat**